



burkert









A rotork Brand

Fine Controls have been supplying process controls & instrumentation equipment since 1994, & now serves an ever expanding customer base, both in the UK & globally.

We offer a full range of valve & instrumentation products & services, with our product rangerepresenting leading technologies & brands:

Flow: Flow Meters & Transmitters, Flow Switches, Flow Control Valves & Batch Control Systems

Temperature: Temperature Probes & Thermowells, Temperature ransmitters, Temperature Regulators & Temperature Displays

Level: Level Transmitters & Switches

Pressure: Pressure Gauges & Transmitters, Precision & High Pressure Regulators & I-P Converters, Volume boosters.

Precision Pneumatics: Pressure Regulators, I-P Converters, Volume Boosters, Vacuum Regulators

Valves: Solenoid & Pneumatic Valves, Control Valves & Positioners, Actuated Ball, Globe or Diaphragm Valves & Isolation Valves

Services: Repair, Calibration, Panel Build, System Design & Commissioning



A rotorik Brand



Honeywell



Baumer Group









Fine Controls (UK) LTD, Bassendale Road, Croft Business Park, Bromborough, Wirral, CH62 3QL UK Tel: 0151 343 9966 Email: sales@finecontrols.com

FAIRCHILD MODEL 10 PNEUMATIC PRECISION REGULATOR Installation, Operation and Maintenance Instructions




Figure 1. Model 10 Pneumatic Pressure Regulator Identification Number System.

GENERAL INFORMATION

The Model 10 is a high capacity regulator that provides a uniform output pressure independent of supply pressure variation.

ADJUSTMENTS

The Model 10 Regulator does not require field adjustments.

SPECIFICATIONS

Functional Specifications				
Supply Pressure	psig	[BAR]	(kPa)	
Maximum (A Option)	500 75	[35] [5.0]	(3500) (500)	

Specifications (continued)

Flow Capacity (Nominal)	40 SCFM (68m ^{3/} HR) @ 100 psig [7 BAR] (700 kPa) Supply & 20 psig [1.5 BAR] (150 kPa) Set.		
Exhaust Capacity	5 1/2 SCFM (9.4m ³ /HR) @ downstream pressure 5 psig [.35 BAR] (35 kPa) above 20 psig [1.5 BAR] (150 kPa) Set Pressure.		
Sensitivity	Less than 0.125" (.32 cm) Water Column		
Ambient Tem- perature Limits	-40 °F to +200° F (-40° C to +93.2° C)		
Performance Specifications			
Supply Pressure Effect	Less than .1 psig [.007 BAR] (.7 kPa) for 100 psig [7 BAR] (700 kPa) Change.		
Materials of Construction	Body and Housing Aluminum Trim Stainless Steel, Brass, Zinc Plated Steel DiaphragmsBuna N on Dacron (Standard Unit Only)		

INSTALLATION


Clean all pipelines to remove dirt and scale before installation.

Apply a minimum amount of pipe compound to the male threads of the fitting only. Start with the third thread back and work away from the end of the fitting to avoid the possibility of contaminating the regulator. Install the regulator in the air line.

You can mount the Model 10 reguator in any position without affecting its operation. To panel mount the unit, use the two 1/4"-20 holes in the bonnet. You can wall mount the regulator using using Mounting Bracket 09921 shown in Figure 3.

The inlet and outlet connections are labeled on the underside of the regulator with the arrows pointing in the direction of the flow. Tighten connections securely. Avoid undersized fittings that will limit the flow through the regulator and cause a pressure drop downstream. For more information, see Figure 2. "Outline Dimensions".

NOTE: Oil free air must be applied to the regulator. Use a filter to remove dirt and entrained liquid in the air line ahead of the regulator. If an air line lubricator is used, it MUST be located downstream of the regulator, to avoid interference with regulator performance.






Figure 4. Exploded Drawing

MAINTENANCE

To clean the Model 10, use the following procedure:

- 1. Before dissassembly, shut off the valve that is supplying air to the regulator. This is to prevent air from escaping. It is not necessary to remove the regulator from the air line.
- 2. Remove the two Screws (22) from bottom of the unit.
- **3.** Pull out the Inner Valve Assembly (19). Wash the Seat on the Inner Valve Assembly carefully.
- 4. Wipe off any particles that may be attached to rubber Seat Ring (17) in Body.
- 5. Replace the assembly carefully.
- 6. Keep the vent hole in the Bonnet clear for proper regulator operation. Lubricate the adjusting screw with Molycote "G". For more information, see Figure 4. "Exploded Drawing" on page 3.

NOTES: Avoid such solvents as acetone, carbon tetrachloride and trichlorethylene.

If the standard maintenance procedure does not correct the problem install service kit.

TROUBLE-SHOOTING

Table 1. Trouble-Shooting		
Problem	Solution (check)	
Leakage	Body Screw tightness. Diaphragm.	
High Bleed	Relief Pintle and Relief Seat for damage or contamination.	
Valve Chatter	Seal Ring lubrication.	

HAZARDOUSLOCATION INSTALLATIONS

Table 2. Hazardous Location		
Information Required	Description Detail	
Hazardous Locations	Group II, Category 2, Gas	
	and Dusts: Zones 1, 2 and	
	21,22, respectively Gas	
	Groups IIA and IIB	
Ambient Temperature	Use must be evaluated	
Range	for the relevant flammable	
	gas temperature code	
Cleaning	Clean with damp cloth	
Grounding	Units must be grounded	
	to earth ground	
Codes of Practice	PDCLC/TR 50404:2003	
	BS 5958	

LEGAL NOTICE

The information set forth in the foregoing Installation, Operation and Maintenance Instructions shall not be modified or amended in any respect without prior written consent of Fairchild Industrial Products Company. In addition, the information set forth herein shall be furnished with each product sold incorporating Fairchild's unit as a component thereof.





Fairchild Industrial Products Company 3920 West Point Blvd .• Winston-Salem, NC 27103 phone: (336) 659-3400 • fax: (336) 659-9323 sales@fairchildproducts.com • www.fairchildproducts.com



IS-10000010 Litho in USA Rev. T 11/05